



HEIGHT	X	WIDTH	PREFILTER	HEPA SECTION	POSTFILTER	
.5=15 1/4"	_____	.5=12 1/8"	_____	2P = 2" _____	12H2424= 24 X 24 X 11 1/2	2P = 2" _____
1=27 1/4"	_____	1 =24 1/8"	_____	4P = 4" _____	HEPA	4P = 4" _____
1.5=40 1/4"	_____	1.5 =37 1/2"	_____			
2 = 52 1/2"	_____	2 = 48 1/4"	_____			
2.5 = 65 3/4"	_____	2.5 =60 3/8"	_____			
3 = 77 3/4"	_____	3 = 72 3/8"	_____			
3.5 = 91"	_____	3.5 = 84 1/2"	_____			
4 = 103"	_____	4 = 96 1/2"	_____			

DEPTH OF UNITS

HEPA ONLY	24 3/4"
2" PREFILTER WITH HEPA	29 3/4" _____
4" PRE FILTER WITH HEPA	31 3/4" _____

WHEN ADDING POST FILTERS
ADD TO DEPTH OF UNIT

2" POST ADD	6 5/8" _____
4" POST ADD	8 5/8" _____

MODEL# SAMPLE: 2X2- 2P-12HEPA24X24-2P
(48 1/4 WIDE X 52 1/2 HEIGH X 37 3/8" DEEP = 2" PREFILTER -12 H24X24 - 2" POST FILTER)

WHEN ORDERING
MODEL# _____ **X** _____ - _____ - _____ - _____

NOTE: MODEL SHOWN: 2X2 2P-12HEPA24X24
DOORS ONE SIDE

SPECIFICATIONS

MADE FROM 16 GAUGE
ALL HOUSING STITCH WELDED AND CAULKED
FINISH:
CRS POWDER COATED _____
ALUMINIZED STEEL _____
STAINLESS STEEL 304 _____

PRE / POST FILTER SIZES:
(3/8 GASKET ON SIDE RECOMMENDED)
2" PRE-POST 23 3/8 X 23 3/8 X 1 3/4
4" PRE-POST 23 3/8 X 23 3/8 X 3 3/4

HEPA SIZE:
HALF SIZE 12 X 24 X 11 1/2
FULL SIZE 24 X 24 X 11 1/2

HEPA SECTION CRANK LOCK OR BOLT LOCK POSITIVE SEAL
CRANK LOCK _____
SPRING BOLT LOCK _____

STANDARD HOUSING HAS DOORS TWO SIDE
HINGED FROM PRE FILTER SIDE

DOORS GASKETED CLOSE CELL FOR POSITIVE SEAL

SPRING KNOBS FOR POSITIVE PRESSURE

LIFT OFF HINGES FOR EASY REMOVAL OF DOORS
(MADE FROM 304 S.S)

OPTIONAL:
DOUBLE WALL INSULATED _____
TAPS AND PLUGS FOR GAUGES EACH SECTION _____
TAPS AND MAG GAUGES INSTALLED _____

DRAWN mfulker	12/10/2014	INDUSTRY AIR SALES		
CHECKED		TITLE CRANK LOCK HEPA		
TOLERANCE:	+/- 1/8	SIZE C	DWG NO 2x2 2p-12HEPA 24X24	REV B
SQUARNESS	+/- 1/8	SCALE	SHEET 1 OF 1	